
Severn Trent Water

SEVERN TRENT WATER Ltd
Leicester Water Centre
Gorse Hill
Leicester LE7 7GU

Tel 0116 2343834
Fax 0116 2343035

Direct Line 0116 2343255

Contact Michael Shapland
Your Ref PA/2009/1003
Our Ref MS1830

25 August 2009

North Lincs District Council,
Church Square House,
P.,O. Box 42,
Scunthorpe,
DN15 6XQ

For the attention of David Wordsworth

Dear Sirs

Re: Application No. PA/2009/1003
Land at Market Place, High Street & Johnsons Lane Crowle

With reference to the above planning application the company's observations regarding sewerage are as follows.

I confirm that Severn Trent Water Limited has NO OBJECTION to the proposal subject to the inclusion of the following condition.

Condition 1

There are public sewers which cross the site. No building shall be erected or trees planted within 3 metres of these sewers. The applicant may wish to apply to Severn Trent Water to divert the sewers in accordance with section 185 of the Water Industry Act 1991 or for a Building Over or Close to a Public Sewer Agreement.

Reason


To maintain essential access for maintenance, repair, renewal and to protect the structural integrity of the public sewerage system.

If you require any further information please contact us on 0116 2343834.

Yours faithfully



Bill Walton
Asset Protection Manager
Asset Protection - Waste Water (East)



A member of the Severn Trent Group

