


From: "Ingham, Daniel" <Daniel.Ingham@nationalgrid.com>
To: "planning@northlincs.gov.uk" <planning@northlincs.gov.uk>

Date: 18 December, 2012 12:18PM
Subject: PA/2012/ 1259



Hi,

Apologies for the lateness of my reply, but we had issues with the delivery of the paper enquiry notes you sent in.

Regarding the above application, there is an Intermediate Pressure Gas Pipeline running along the east boundary of the plot. Any housing will have to built a sufficient distance from the pipeline, at a minimum of 3m away to adhere to our easement.

Thanks

Regards,
Daniel Ingham
Network Supervisor (Pipelines)
National Grid Gas - East Midlands
07798636297
daniel.ingham@nationalgrid.com

This e-mail and any files transmitted with it, are confidential to National Grid and are intended solely for the use of the individual or entity to whom they are addressed. If you have received this e-mail in error, please reply to this message and let the sender know.

Attachments:
Barton.doc

