

# Evaluation Report

## HAZOP Study of the Paint R&D Facility – Jotun Flixborough

**Document Number: C2493-PE-HZ-001**

**Revision: 1.0**

**Date: 25<sup>th</sup> November 2015**

Written by: R. Preston                      MBA, BEng(Hons), CEng, FIMechE

Approved by: M Thompson                MBA, BSc(Hons), CEng, MIET

## Contents

1. Introduction
  2. Glossary of Terms
  3. The Site
  4. Scope of Work and Methodology
  5. HAZOP Action & Study
  6. Conclusions & Recommendation
- Appendices

## 1. Introduction

As part of the initiative to continuously improve Health & Safety standards, Jotun has undertaken an evaluation of the proposed new R&D Facility to be built in 2016, with the aim of identify the potential Health, Safety and Operational risks associated with operating the processes and systems with regards to UK legislation and Jotun Policies and Procedures. With reference to, but not confined to, The Control of Substances Hazardous to Health 2002 (COSHH); and the Provision and Use of Work Equipment Regulations 1998 (PUWER). The primary purpose of COSHH is to prevent or limit the exposure to hazardous chemicals and atmospheres for workers and all those who maybe affected. PUWER is to ensure equipment has been installed, operated and is maintained correctly and operated by trained competent persons. The key requirement is to identify the risks and hazards, then assess and eliminate or reduce them, following the Hierarchy of control principles.

This evaluation report contains the methodology used, the action required to mitigate the risks identified and further recommendations and conclusions to enable the changes and improvements to the process line and area. The report details the findings of the study using well documented what, when, how, why philosophy and the use of key words to extract the operating\hazardous scenarios present during start-up and operation.

The report was produced by Robert Preston MBA, BEng(Hons),CEng, FIMechE who has experience gained across a wide spectrum of Engineering and manufacturing environments

The HAZOP team members are listed below

Robert Preston	- HAZOP Chair – IRIS Engineering & Technology
David Hutchinson	- M&E Design (IRIS)
Daniel Kavenagh	- Structural & Architectural Designer ( Head Office3)
Richard Mann	- R&D Manager (Jotun)
Darren Dawson	- HSE Legal Compliance Specialist (Jotun)

## 2. Glossary of Terms

BS	-	British Standard
CE	-	CE marking
COSHH	-	Control of Substances Hazardous to Health
FSD	-	Functional System Description
HAZOP	-	Hazard Operability Study
HSE	-	Health and Safety Executive
IEC	-	International Electrotechnical Committee
MSDS	-	Material Safety Data Sheet
URS	-	User Requirement Specification
P\T	-	Pressure Test
PUWER	-	Provision and Use of Work Equipment Regulations
LEV	-	Local Exhaust Ventilation
IBC	-	Intermediate Bulk Container

## 3. The Location

The R&D Facility will be a unique facility enabling Jotun to develop new standard and intumescent paints for industrial applications.

The project continues to strengthen the product development within Jotun and the centre will work with others to further develop antifouling for ships. This will keep Jotun in a leading position in the marine market.

#### **4. Scope of Work and Methodology**

As part of the commitment to meeting Jotun's minimum standards and legislative compliance, it was identified by the Project Team that a HAZOP study was required to enable the sign off of the new equipment by the Safety Team. The HAZOP undertaken over an intense one day period covering the building and process within

The scope of this study has been broken down into 8 discrete nodes enabling specific analysis of the risk and mode of operation to be undertaken. Appendix 1 identifies The Layout of the area

The nodes are a listed as follows:

- |        |                                   |
|--------|-----------------------------------|
| Node 1 | - Storage & Material Distribution |
| Node 2 | - Mixing Mill Room                |
| Node 3 | - Sample Storage Room             |
| Node 4 | - Hand Application                |
| Node 5 | - Spray Booth 1 & 2               |
| Node 6 | - Conditioning Room               |
| Node 7 | - Grinding Room                   |
| Node 8 | - General Area & Furnace Controls |

## 5. HAZOP Action & Study Sheets

### Node 1 - Storage & Materials

Project	Jotun R&D Paint Facility				Table number: 1		Action by		
Line No and Node	Guide word	Deviation	Ref	Cause	Consequence	Comment	Actions required	Person	Risk
Storage & Material Distribution	Steel	Movements	1.01	Palletised Material	1m x 75 kg - 4.5m x 240kg	Offloaded from pallet via 5T overhead crane onto transport jig	New Personnel will require in-house training for management of vehicle movements. Training required for crane operations	RM	
	Steel	Movements	1.02	Palletised Material		Offloaded from transport via Fork Lift Truck and moved into paint area	New Personnel will require in-house training for management of vehicle movements	RM	
	Paint Raw Materials	Storage Liquids	1.03	Decanting material	Spillage	No Liquids above 20 litres without a bunded pallet	Spill Kits required within decanting area	DD	
	Paint Raw Materials	Storage Liquids	1.04	Decanting material	Spillage	200 litre drum to be stored on bunded pallet	Purchase and located bund pallets	DD	
	Paint Raw Materials	Storage Liquids	1.05	Decanting material	Spillage	Solvents will be provided in 20ltr drums from the main plant these will be transported via approved movements in sealed containers - no decanting within facility	No action		
	Paint Raw Materials	Powders	1.06	Decanting material	Flammable atmosphere	Materials will be moved in 20lts bags and dispensed within ATEX rated Area with appropriate LEV	No action		

## Node 2 - Mixing\Mill Room

Project	Jotun R&D Paint Facility				Table number: 2		Action by		
Line No and Node	Guide word	Deviation	Ref	Cause	Consequence	Comment	Actions required	Person	Risk
Mixing\Mill Room	Mixing	Ventilation	2.01	Loss of Vent	Loss of ATEX zone	Design allows for pressure measurement and doors interlocked with an agreed time delay. Alarm within area to advise operator to stop activities if pressure control is compromised	Training required as part of Operations	RM	
	Mixing	Ventilation	2.02	Loss of Vent	Loss of ATEX zone	Machine to be interlocked so as activities cannot be undertaken if zone compromised either via pressure loss or doors left open	Set time control as part of commissioning activities	M&E Designers	
	Mixing	ATEX	2.03	Equipment classification	Ignition source	All equipment to be zone 1 rated	Ensure Zone 1 specified as part of equipment specification\installation order	RM	
	Flam Liquids	Storage	2.04	Spillage	loss of containment	Purchase banded flam cabinet for solvents	Purchase banded flammable cabinet for solvents	RM	
	PPE	Anti static	2.05	Zoned Area	Ignition source	All clothing within the area to be antistatic with correct signage and personnel earth proving before entry	No action		
	Static\access control	Anti static	2.06	Zoned Area	Ignition source	Move Test point from stairs to zone corridor and add additional point to operational corridor, interlock good in\out roller door with Operational corridor roller door	Modify design to comply	M&E Designers	
	Product	Spill	2.09	Drop of 20 litre tin within area	Potential for flammable atmosphere	Spill kit required to give spill volume protection and correct type of fluids	Provide kit and training for use	RM	
	Water Dispense	Spill	2.10	Dispense of mains water	Leak onto floor	Spring loaded dispense tap required with mechanical isolation	Install water supply and tap with drip tray below	M&E Designers	
	ATEX	Conductivity	2.11	Atex compliance	Ignition source	Floor to be conductive construction and certified as built	Ensure full test and certification required	M&E Designers	

### Node 3 – Sample Storage

Project	Jotun R&D Paint Facility				Table number: 3		Action by		
Line No and Node	Guide word	Deviation	Ref	Cause	Consequence	Comment	Actions required	Person	Risk
Sample Storage Room	Storage		3.01		No Hazardous Consequence	Only 25% of product stored in the area will be flammable - No decanting or transport of material in open containers - unless within an ATEX zone	No action required		

### Node 4 - Hand Application

Project	Jotun R&D Paint Facility			Table number: 4			Action by		
Line No and Node	Guide word	Deviation	Ref	Cause	Consequence	Comment	Actions required	Person	Risk
Hand Application	Comment	Other	4.01			Mainly Solvent free however design as zone 1 to allow flexibility	No action required		
	Ventilation	Loss	4.02	Loss of Vent	Loss of ATEX zone	Design allows for pressure measurement and doors interlocked with an agreed time delay with alarm within area to advise operator to stop activities if pressure control or door is compromised	Training required as part of Operations	RM	

### Node 5 – Spray Booths 1 & 2

Project	Jotun R&D Paint Facility				Table number: 5			Action by	
Line No and Node	Guide word	Deviation	Ref	Cause	Consequence	Comment	Actions required	Person	Risk
Spray Booth 1 & 2	Ventilation	Loss	5.01	Loss of Vent	Loss of ATEX zone	Design allows for pressure measurement and doors interlocked with an agreed time delay with alarm within area to advise operator to stop activities if pressure control or door is compromised	Training required as part of Operations	RM	
	Pressure Control	Room Access	5.02	Door locks	Access During Spraying	Doors need to be locked during activity with external manual override	Design to be reviewed at build stage	M&E Designers	
	ATEX	Conductivity	5.03	Atex compliance	Ignition source	Floor to be conductive construction and certified as built	Ensure full test and certification required	M&E Designers	
	PPE	Anti static	5.04	Zoned Area	Ignition source	All clothing within the area to be antistatic with correct signage and personnel earth proving before entry		RM & M&E Designers	
	ATEX	Anti static	5.05	Zoned Area	Ignition source	If break glass activated then compressed air to room isolated	Design to be reviewed at build stage	M&E Designers	
	Booth Design	ATEX	5.06	Zoned Area	Ignition source	Booth design to be finalised to confirm air flow design dilution calculation to define ATEX of extracts	Build designer to finalise ATEX report once equipment specification is finalised	M&E Designers	
	ATEX	Earthing	5.07	Drum & pump units no earthed correctly	ignition source	Add additional earth proving unit to equipment	4 proving units required per room	M&E Designers	

### Node 6 – Conditioning Room

Project	Jotun R&D Paint Facility			Table number: 6			Action by		
Line No and Node	Guide word	Deviation	Ref	Cause	Consequence	Comment	Actions required	Person	Risk
Conditioning Room	ATEX	Conductivity	6.01	Atex compliance	Ignition source	Floor to be conductive construction and certified as built	Ensure full test and certification required	M&E Designers	
	Ventilation	Loss	6.02	Loss of Vent	Loss of ATEX zone	Design allows for pressure measurement and doors interlocked with an agreed time delay with alarm within area to advise operator to stop activities if pressure control or door is compromised	Training required as part of Operations	RM	

### Node 7 – Grinding Room

Project	Jotun R&D Paint Facility			Table number: 7				Action by	
Line No and Node	Guide word	Deviation	Ref	Cause	Consequence	Comment	Actions required	Person	Risk
Grinding Room									
	Ventilation	Loss	7.01	Loss of Vent	Dust Control	Design allows for pressure measurement and doors interlocked with an agreed time delay with alarm within area to advise operator to stop activities if pressure control or door is compromised	Training required as part of Operations	RM	
	Dust Control	Door Control	7.02	Dust	Dirt within clean areas	Doors to be interlocked with booth operation - doors lock when in use	Implement Design as part of build	M&E Designers	

### Node 8 – General Area & Furnace Controls

Project Jotun R&D Paint Facility				Table number: 8			Action by		
Line No and Node 8	Guide word	Deviation	Ref	Cause	Consequence	Comment	Actions required	Person	Risk
General Area & Furnace Control Interfaces	Spillage	Salt Spray Room	8.01	Spillage in Large Lab	Contamination of sewer		Design bund lip to salt spray room to stop liquids entering this room	Head Office	
	Working at Height	Furnace and filter System access	8.02	Hand Rails removed for potential hard product	Fall		Review handrails and safety clip on details if rails removed	RM	
	Liquid N2	Spill Test	8.03	Normal Activity	asphyxiation		Asphyxiation risk assessment for test	RM	
	Furnace Control	Other	8.04	Manage activity & assess during fire test	Pressure Control to area	Minimum of 2 volt free contacts required to manage door control and compressor air flow control	Confirm with Supplier	RM	
	Furnace Control	Other	8.05	Furnace/Filter Interface	Combustion products within building	The 2 units are from different suppliers and therefore clear controls interface is required	A full and signed off design is required between both parties including interfaces to Facilities systems	All	

## 6.0 Conclusions & Recommendations

The R&D facilities has been assessed to identify, and propose engineering solutions and operational actions that could be implemented to reduce possible hazard scenarios identified by the team during the HAZOP Study. Individual actions are identified in the study sheets and when implemented should offer both operational safety and process functionality improvements. The control measures must be implemented using robust engineering design and installation procedures documented via the Jotun change control procedures.

## 7. Bibliography

- Dangerous Substances and Explosive Atmospheres Regulations 2002 (DSEAR)
- L136DSEAR Approved Code of Practice and Guidance for Control and Mitigation Measures.
- Control of Substances Hazardous to Health Regulations 2002 (COSHH)
- Provision and Use of Work Equipment Regulations 1998 (PUWER)
- EH40/2005 Workplace exposure limits: Containing the list of workplace exposure limits for use with the Control of Substances Hazardous to Health Regulations 2002 (as amended).
- CISHEC/8906/1000 CIA Guide to Hazard and Operability Studies
- Kietz T.A HAZOP and HAZAN Identifying and Assessing Process Industry Hazards 3<sup>rd</sup> Edition 1992.

## Appendix 1 – Jotun Drawings

