

PA/2017/367

Michael.Shapland@severntrent.co.uk on behalf of net.dev.east@severntrent.co.uk

Tue 28/03/2017 12:55

To: Planning <Planning@northlincs.gov.uk>;

Our Ref: 2017032248902

Dear James Roberts

Thank you for your consultation with regards to the application above.

Having reviewed our sewer records and the enclosures provided, I can confirm the condition can be discharged.

Foul is proposed to connect into the public sewer, which would require a section 106 sewer connection approval.

Surface water to connect into soakaways, for which we have no comment.

Should you require any further information please contact us on the telephone number or email below.

Yours Faithfully,

**Asset Protection Waste Water East
Wholesale Operations
Severn Trent Water Ltd**

Tel: 024 7771 6843

(reply to email: Planning.APEast@severntrent.co.uk)

Severn Trent Plc (registered number 2366619) and Severn Trent Water Limited (registered number 2366686) (together the "Companies") are both limited companies registered in England & Wales with their registered office at Severn Trent Centre, 2 St John's Street, Coventry, CV1 2LZ

This email (which includes any files attached to it) is not contractually binding on its own, is intended solely for the named recipient and may contain CONFIDENTIAL, legally privileged or trade secret information protected by law. If you have received this message in error please delete it and notify us immediately by telephoning +44 2477715000. If you are not the intended recipient you must not use, disclose, distribute, reproduce, retransmit, retain or rely on any information contained in this email. Please note the Companies reserve the right to monitor email communications