

3/26/2020

RE: Planning Consultation - PA/2019/1235 - Planning

RE: Planning Consultation - PA/2019/1235

McParland, Brian (Capita) <Brian.McParland@capita.com>

Wed 25/03/2020 17:29

To: Planning <Planning@northlincs.gov.uk>;

Thanks for these Clare.

Regards

Brian Mc Parland BSc. MSc.
Planner, Town Planning
Town Planning
Capita, Belfast
Email: Brian.McParland@capita.com
Address: The Metro Building, 6-9 Donegall Square South, Belfast, BT1 5JA



From: Planning <Planning@northlincs.gov.uk>
Sent: 25 March 2020 16:57
To: McParland, Brian (Capita) <Brian.McParland@capita.com>
Subject: Fw: Planning Consultation - PA/2019/1235

Kind Regards

Clare

Development Management

North Lincolnshire Council

Church Square House

30-40 High Street

SCUNTHORPE

DN15 6NL

Tel: 01724 297000

Please let us know what you think about the customer service you received during your enquiry by completing our customer satisfaction survey on our Consultations Page on the council web site: <http://ow.ly/4mNWDJ>



From: Phillips Stephen <Stephen.Phillips3@networkrail.co.uk>
Sent: 14 August 2019 17:12
To: Planning
Cc: Rivero Tony
Subject: Planning Consultation - PA/2019/1235

Dear Sir/Madam,

Application No: PA/2019/1235
Proposal: Planning permission to redevelop the existing dwelling including the erection of a two storey link extension, erection of replacement garage, works of demolition and other alterations
Site Location: Crossing Cottage, Gatehouse Road, Goxhill, DN19 7LS

Thank you for your letter dated 6 August 2019, providing Network Rail with an opportunity to comment on the aforementioned application.

With reference to the protection of the railway, Network Rail has no objection in principle to a development of this type at this location but cannot support the proposals in the current format. This is because the development as proposed appears to be partly located on an area of land still in the ownership of Network Rail. The attached plan shows the land in Network Rail's ownership (shaded green).

It is therefore appropriate that the applicant re-submit the redline plan showing the correct boundary or contact Network Rail at landinformation@networkrail.co.uk to discuss the boundary issue and reach agreement.

The following are requirements which must be met when considering this type of development at this location.

Drainage

All surface and foul water arising from the proposed works must be collected and diverted away from Network Rail property. In the absence of detailed plans all soakaways must be located so as to discharge away from the railway infrastructure. The following points need to be addressed:

1. There should be no increase to average or peak flows of surface water run-off leading towards Network Rail assets, including earthworks, bridges and culverts.
2. All surface water run-off and sewage effluent should be handled in accordance with Local Council and Water Company regulations.
3. Attenuation should be included as necessary to protect the existing surface water drainage systems from any increase in average or peak loadings due to normal and extreme rainfall events.
4. Attenuation ponds, next to the railway, should be designed by a competent specialist engineer and should include adequate storm capacity and overflow arrangements such that there is no risk of flooding of the adjacent railway line during either normal or exceptional rainfall events.

It is expected that the preparation and implementation of a surface water drainage strategy addressing the above points will be conditioned as part of any approval.

Excavations/Earthworks

All excavations/ earthworks carried out in the vicinity of Network Rail property/ structures must be designed and executed such that no interference with the integrity of that property/ structure can occur. If temporary works compounds are to be located adjacent to the operational railway, these should be included in a method statement for approval by Network Rail. Prior to commencement of works, full details of excavations and earthworks to be carried out near the railway undertaker's boundary fence should be submitted for the approval of the Local Planning Authority acting in consultation with the railway undertaker and the works shall only be carried out in accordance with the approved details. Where development may affect the railway, consultation with the Asset Protection Project Manager should be undertaken. Network Rail will not accept any liability for any settlement, disturbance or damage caused to any development by failure of the railway infrastructure nor for any noise or vibration arising from the normal use and/or maintenance of the operational railway. No right of support is given or can be claimed from Network Rail's infrastructure or railway land.

Security of Mutual Boundary

Security of the railway boundary will need to be maintained at all times. If the works require temporary or permanent alterations to the mutual boundary the applicant must contact Network Rail's Asset Protection Project Manager.

Fencing

It should be noted that our fence should not be altered or moved in any way and nothing should be put in place to prevent us from maintaining our boundary fence as we are obliged to do so in law. It is our experience that most developments seek to provide their own boundary enclosure so as to avoid such future problems. It would also help to reduce the impact of railway noise. We would advise that the developer should provide a trespass proof fence adjacent to Network Rail's boundary (minimum 1.8m high) and make provision for its future maintenance and renewal. Network Rail's existing fencing / wall must not be removed or damaged.

Method Statements/Fail Safe/Possessions

Method statements may require to be submitted to Network Rail's Asset Protection Project Manager at the below address for approval prior to works commencing on site. This should include an outline of the proposed method of construction, risk assessment in relation to the railway and construction traffic management plan. Where appropriate an asset protection agreement will have to be entered into. Where any works cannot be carried out in a "fail-safe" manner, it will be necessary to restrict those works to periods when the railway is closed to rail traffic i.e. "possession" which must be booked via Network Rail's Asset Protection Project Manager and are subject to a minimum prior notice period for booking of 20 weeks. **Generally if excavations/piling/buildings are to be located within 10m of the railway boundary a method statement should be submitted for NR approval.**

OPE

Once planning permission has been granted and at least six weeks prior to works commencing on site the Asset Protection Project Manager (OPE) MUST be contacted, contact details as below. The OPE will require to see any method statements/drawings relating to any excavation, drainage, demolition, lighting and building work or any works to be carried out on site that may affect the safety, operation, integrity and access to the railway.

OR

Once planning permission has been granted and prior to the commencement of any works on site, developers must contact Network Rail to inform them of their intention to commence works. This must be undertaken a minimum of 6 weeks prior to the proposed date of commencement. Please contact the Asset Protection Project Manager at the address below.

Demolition

Any demolition or refurbishment works must not be carried out on the development site that may endanger the safe operation of the railway, or the stability of the adjoining Network Rail structures. The demolition of buildings or other structures near to the operational railway infrastructure must be carried out in accordance with an agreed method statement. Approval of the method statement must be obtained from Network Rail's Asset Protection Project Manager before the development can commence.

Vibro-impact Machinery

Where vibro-compaction machinery is to be used in development, details of the use of such machinery and a method statement should be submitted for the approval of the Local Planning Authority acting in consultation with the railway undertaker prior to the commencement of works and the works shall only be carried out in accordance with the approved method statement

Scaffolding

Any scaffold which is to be constructed within 10 metres of the railway boundary fence must be erected in such a manner that at no time will any poles over-sail the railway and protective netting around such scaffold must be installed

Two Metre Boundary

Consideration should be given to ensure that the construction and subsequent maintenance can be carried out to any proposed buildings or structures without adversely affecting the safety of, or encroaching upon Network Rail's adjacent land, and therefore all/any building should be situated at least 2 metres from Network Rail's boundary. This will allow construction and future maintenance to be carried out from the applicant's land, thus reducing the probability of provision and costs of railway look-out protection, supervision and other facilities necessary when working from or on railway land.

ENCROACHMENT

The developer/applicant must ensure that their proposal, both during construction, and after completion of works on site, does not affect the safety, operation or integrity of the operational railway, Network Rail and its infrastructure or undermine or damage or adversely affect any railway land and structures. There must be no physical encroachment of the proposal onto Network Rail land, no over-sailing into Network Rail air-space and no encroachment of foundations onto Network Rail land and soil. There must be no physical encroachment of any foundations onto Network Rail land. Any future maintenance must be conducted solely within the applicant's land ownership. Should the applicant require access to Network Rail land then must seek approval from the Network Rail Asset Protection Team. Any unauthorised access to Network Rail land or air-space is an act of trespass and we would remind the council that this is a criminal offence (**s55 British Transport Commission Act 1949**). Should the applicant be granted access to Network Rail land then they will be liable for all costs incurred in facilitating the proposal.

Noise/Soundproofing

The Developer should be aware that any development for residential use adjacent to an operational railway may result in neighbour issues arising. Consequently every endeavour should be made by the developer to provide adequate soundproofing for each dwelling. Please note that in a worst case scenario there could be trains running 24 hours a day and the soundproofing should take this into account

Access to Railway

All roads, paths or ways providing access to any part of the railway undertaker's land shall be kept open at all times during and after the development.

Network Rail is required to recover all reasonable costs associated with facilitating these works.

I would advise that in particular the **drainage, boundary fencing, method statements and soundproofing** should be the subject of conditions, the reasons for which can include the safety, operational needs and integrity of the railway. For the other matters we would be pleased if an informative could be attached to the decision notice.

I trust full cognisance will be taken in respect of these comments. If you have any further queries or require clarification of any aspects, please do not hesitate to contact myself I would also be grateful if you could inform me of the outcome of this application, forwarding a copy of the Decision Notice to me in due course.

The method statement will need to be agreed with:

**Asset Protection Project Manager
Network Rail (London North Eastern)
Floor 3B
George Stephenson House
Toft Green
York
YO1 6JT**

Email: assetprotectionlneem@networkrail.co.uk

Kind Regards

Stephen Phillips BSc (Hons)
Graduate Surveyor | Property
George Stephenson House, Toft Green, York, YO1 6JT
E: stephen.phillips3@networkrail.co.uk
W: www.networkrail.co.uk/property



Property

The content of this email (and any attachment) is confidential. It may also be legally privileged or otherwise protected from disclosure. This email should not be used by anyone who is not an original intended recipient, nor may it be copied or disclosed to anyone who is not an original intended recipient.

If you have received this email by mistake please notify us by emailing the sender, and then delete the email and any copies from your system.

Liability cannot be accepted for statements made which are clearly the sender's own and not made on behalf of Network Rail. Network Rail Infrastructure Limited registered in England and Wales No. 2904587, registered office Network Rail, 2nd Floor, One Eversholt Street, London, NW1 2DN

This e-mail expresses the opinion of the author and is not necessarily the view of the Council. Please be aware that anything included Please think before you print- North Lincolnshire Council greening the workplace.

This message has been scanned by Capita's systems, but if you believe it to be spam then click [here](#) to report this email as spam.

This email is security checked and subject to the disclaimer on web-page: <https://www.capita.com/email-disclaimer.aspx>