

Discharge of Condition

no-reply-InFlow@anglianwater.co.uk

Wed 01/09/2021 13:24

To: Planning <Planning@northlincs.gov.uk>;

 Anglian water logo image

Dear Tanya Coggon

**Former Falcon Cycles, Bridge Street, Brigg, DN20 8NQ,
PA/2021/1466, PLN-0129999**

Thank you for your enquiry to discharge condition relating to the above development site. Please find our comments below.

Foul Water Comments: The drawing provided (111-2100-CIV-10 P1), does not show where the foul intends to connect into the existing public sewer. We are not able to assess and confirm acceptability of the proposed strategy and cannot recommend discharge of condition 12 at this time for the foul water strategy.

Surface Water Comments: The drawing provided (111-2100-CIV-10 P1), does not show proposed connection points, nor a proposed discharge rate into the public sewer system. Neither has any evidence that the surface water hierarchy has been followed. we at this time are not able to recommend discharge of the surface water element of condition 12.

Should you have any queries or comments regarding this please contact us at planningliaison@anglianwater.co.uk or 07929 786 955 quoting reference PLN-0129999.

Kind Regards

Development Services Pre-Development Team

Not you or need help?

Call us on **0345 60 66 087**



