

FW: [EXTERNAL] RE: PA/2023/421 + PA/2023/422

Rebecca Leggott

Wed 31/05/2023 12:10

To: Planning <Planning@northlincs.gov.uk>

Please could this be added to both files.

Regards,

Rebecca

Development Management Lead
Economy & Growth
Business Development
North Lincolnshire Council

From: Lyons, Andrew

Sent: Monday, May 22, 2023 3:05 PM

Subject: RE: [EXTERNAL] RE: PA/2023/421 + PA/2023/422

You don't often get email from andrew.lyons@nationalgrid.com. [Learn why this is important](#)

Many thanks, Chloe.

No objection from NGET in relation to both applications.

Best regards,

Andrew Lyons

Asset Protection Team Leader
Asset Management – OHL & Cables
Asset Operations
Electricity Transmission
nationalgrid

National Grid House, Warwick Technology Park,
Gallows Hill, Warwick, CV34 6DA (Floor B1)

recognise the sender and know the content is safe. If
utton.

Morning Andrew,

The nearest works are the HV Transformer tie-ins and piping tie-ins, which appear to each be set setback approx. 20m and 120m, respectively as shown below (Drawing ref. 415000-00201-8820-01-0002). The NG substation is shown very roughly in yellow highlighter. The activities will be limited to installation of the transformers at the west and the tie-in to 15.75kV at GTs 1 and 2 as indicated. The only piling in the area will be associated with the transformer foundation.

I hope this provides sufficient clarification.

Chloe