

I N T E R	<h1>MEMO</h1>	North Lincolnshire Council www.northlincs.gov.uk
O F F I C E		

To: Development Management

From: Environmental Protection Team

Your Ref: PA/2023/421

Our Ref: PLU007447

Subject: Planning permission for the construction & operation of a post-combustion carbon capture plant, including carbon dioxide compressor & metering, coding equipment, stacks, substations, internal roads, partial ditch realignment, new & modified services, connections, internal roads, accesses, maintenance & laydown areas

Location: Vpi Power Station, Rosper Road, South Killingholme

Date: 15 January 2024

Further to our memo dated 7 November 2023, the following document has been submitted by the applicant:

- AECOM Ltd, Technical Note Reference: 60712174 dated: 28 November 2023

This department has reviewed the information submitted and we now have the following comments to make:

The above document has been updated to ensure the proposed development does not exceed a maximum cumulative noise level of three decibels above existing background, this department therefore recommend the following condition is included on any planning permission granted, in addition to those previously recommended:

- The cumulative noise level (in terms of the BS4142:2014 rating level) from the operation of the authorised development shall be no greater than 3dB higher than the defined representative background sound level detailed in AECOM Ltd, Technical Note reference 60712174 dated 28 November 2023, during each of the daytime and the night time, adjacent to the nearest residential properties at locations agreed with the relevant planning authority.