



HUMBERSIDE
Fire & Rescue Service

Your Ref: PA/2024/766
Our Ref: FS/DB/MM/S2/TCP/000268 (808300)
Date: Friday 1st November 2024

Millie Arden
North Lincolnshire Council
Church Square House
30-40 High Street
Scunthorpe
DN15 6NL

planning@northlincs.gov.uk

PROTECTION
North Lincolnshire
Laneham Street
Scunthorpe
DN15 6JP
The person dealing with this matter is:
Dave Bottomley

Dear Madam,

TOWN AND COUNTRY PLANNING ACT 1990
PROPOSAL: PLANNING PERMISSION FOR RESIDENTIAL DEVELOPMENT OF UP TO 65 DWELLINGS- APPLICATION TO MODIFY/DISCHARGE THE S106 AGREEMENT ATTACHED TO [PA/2019/1414](#) RELATING TO THE REQUEST FOR CONTRIBUTIONS BE REMOVED FOR VIABILITY REASONS.

**PREMISES: LAND REAR OF
99 NORTH STREET
WINTERTON
DN15 9QW**

APPLICATION NO: PA/2024/766

Further to your electronic consultation received on 30th October 2024 regarding the above-mentioned application, the following comments are made: -

Access for Fire Service

It is a requirement of Approved Document B5, Section 15 Commercial Properties or B5, Section 13 for Domestic Premises that adequate access for firefighting is provided to all buildings or extensions to buildings.

Where it is a requirement to provide access for high reach appliances, the route and hard standing should be constructed to provide a minimum carrying capacity of 26 tonnes.

Water Supplies for Fire Fighting

Adequate provision of water supplies for firefighting appropriate to the proposed risk should be considered. If the public supplies are inadequate, it may be necessary to augment them by the provision of on-site facilities. Under normal circumstances hydrants for industrial unit and high-risk areas should be located at 90m intervals. Where a building, which has a compartment of 280m² or more in the area is being erected more than 100m from an existing fire hydrant, hydrants should be provided within 90m of an entry point to the building and not more than 90m apart. Hydrants for low risk and residential areas should be located at intervals of 240m.

If you require further advice or clarification of any of the above matters, please contact the Protection Inspector at the address above.

Yours faithfully



FOR THE CHIEF FIRE OFFICER & CHIEF EXECUTIVE