

From: Keystone Architecture [REDACTED]
Sent: 20 August 2025 16:16
To: Emmanuel Hiamey <Emmanuel.Hiamey@northlincs.gov.uk>
Subject: CanPack 1964CAN3

CAUTION: External Email. Do not click links or open attachments unless you recognise the sender and know the content is safe.

Hi Emmanuel

Re. PA/2025/735

Just in reference to the above, to clarify in response to the LLFA's comment / objection, the footpath will drain onto the road, to the existing sewer.

This is in accordance with the adoptable road standards where the footpath falls at a slight gradient towards the road kerb – as shown on the drawings / details.

I'm trusting this won't be an issue.

Regards

Jon Bayley
Director

Britannia House, High Street, Scunthorpe, North Lincolnshire, DN15 6EA

t: [REDACTED]

This email and any attachments, may be confidential and are intended solely for the use of the individual to whom it is addressed. Any views or opinions expressed are solely those of the author and do not necessarily represent those of keystone**architecture**. If you are not the intended recipient of this email, you must neither take any action based upon its contents, nor copy or show it to anyone. Please contact the sender if you believe you have received this email in error.